

Phone No. 0761-2622302/2620167
Fax No. 0761-2623872
Email: cbjabalpur@gmail.com



कार्यालय मुख्य अधिशासी अधिकारी
OFFICE OF THE CHIEF EXECUTIVE OFFICER
CANTONMENT BOARD JABALPUR




No.CBJ/Misc Admn/2026/2370

Dated: 17 Mar, 2026

TO WHOM SOEVER IT MAY CONCERN

It is certified that an inspection team headed by Shri A.S. Parihar, Sanitray Inspector, from Cantonment Board, Jabalpur inspected the A.P.N C.B.S.E. SENIOR SECONDARY SCHOOL, Sadar Cantt. Jabalpur on 10-03-2026 and found that the A.P.N C.B.S.E. Senior Secondary School, has safe drinking water facilities for the students and members of the staff of the institution and is maintain the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the State Govt.

~~The above certificate is valid for the period of one year.~~


Chief Executive Officer
Cantonment Board, Jabalpur
(Rajeev Kumar)
I.D.E.S.

DISTRICT WATER TESTING LABORATORY
Office of the Executive Engineer, Public Health Engg. Division Jabalpur M.P.

WATER TESTING REPORT

Report No. 234	Date 17.02.2026	UID No. JBP/
Ref. NO. NIL	Date 16.02.26	Village & Location
To, Principal A.P.N.C.B.R.E. Senior Sec. School Jabalpur Cant.		1- Jabalpur in the campus of APN CBSE Senior Sec. School
Sample Collected by School Staff		2- School Cant-Jabalpur
Date of collection 16.02.2026		3-
Source P.W.S.S.		4-
Date of receipt 16.02.2026		5-
Date of Testing 17.02.2026		
Test conducted by Ku. Karita		

As per BIS 10500:2012 Reaffirmed in feb 2021 For Drinking Water

Sl no.	Characteristic	Unit	Acceptable	Cause for rejection	TEST RESULT				
					1	2	3	4	5
PHYSICAL-TEST									
1	Turbidity	NTU	1.0	5.0	3.5				
2	Colour	Pt. Cobalt	1.0	25.0	2				
3	Taste & Odour	Unobjectionable	Agreeable	Agreeable	Agreeable				
CHEMICAL-TEST									
4	pH	...	6.5 to 8.5	6.5 to 8.5	7.10				
5	Conductivity	M. Mohs/cm	570				
6	Alkalinity	mg/l	200	600	316				
7	Chloride (As cl)	mg/l	250	1000	72				
8	Nitrates	mg/l	45	45	8.2				
9	Total Hardness (As CaCO ₃)	mg/l	200	600	274				
10	Calcium (As Ca)	mg/l	75	200	54				
11	Magnesium (As Mg)	mg/l	30	100	34.0				
12	Total dissolved solid	mg/l	500	2000	370				
13	Iron (As Fe)	mg/l	1.00	1.0	0.30				
14	Manganese (As Mn)	mg/l	0.10	0.30	0.08				
15	Fluoride (As F)	mg/l	1.00	1.50	0.20				
16	Sulphates As So ₄	mg/l	200	400	9.0				
17	Residual Chlorine	mg/l	0.20	1.0	0				
BACTERIOLOGICAL-TEST									
18	Total Coliform	per 100ml	0	..	0				
19	E Coli or Thermo tolerant coliforms	per 100ml	0	..	0				

Remark:-

Note:- 1. As above result compared with BIS 10500:2012

2. Samples are not collected by us.

3. Not to be produced at court of law.

4. We do not take any responsibility for deviation in test result due to wrong collection of sample

[Signature]
17/02/26
Inemist
m Distric Laboratory
P.H.E.Dn. Jabalpur